## DISTRICT OF COLUMBIA BUILDING CODE ADVISORY COMMITTEE

c/o DCRA/BLRA · 941 North Capitol Street, NE, Ste. 2000 · Washington, DC 20002

CODE CHANGE PROPOSAL FORM		2003 ICC FAMILY OF CODES	
PAGE 1 OF 1			
CODE IBC	<b>SECTION NO.</b> 910.3	SUBCOMMITTEE AMENDMEN	NT NO. FLS-7
PROPOSING SUBCOMMITTEE	FLS CHAIR Devlin	PHONE 301/220-1212 E-ma	john_devlin@schirmereng.com
DATES: OF PROPOSAL 04/20/	BCAC PRESENTATIO	ON 04/20/05 BCAC APP	PROVAL
CHECK ONE		☐ Delete section and substitute the following:☐ Delete section without substitution.	
TYPE ALL TEXT IN 12-POINT TIMES NEW ROMAN FONT  LINE THROUGH TEXT TO BE DELETED-(highlight text, under Format, click font and check strikethrough)  UNDERLINE TEXT TO BE ADDED			
Add a footnote "c" to Table 910.	3 to read:		
c. Smoke and heat vents are not sprinklers installed in accordance	required when storage areas are p with NFPA 13 or NFPA 231.	rotected by early suppression fast	response (ESFR)
Anticipated impact of code change	e on cost of construction (CHECK	CONE)	

## JUSTIFICATION OF CHANGE:

**☑**Decrease

If "Increase" box was checked, indicate estimated range of added cost:

Per 1,000 SF single-family dwelling
Per 1,000SF of commercial building \$

☐ *Increase* 

The code provision creates an economic hardship on the owner without a clear justification based on considerations of protection of safety, health and welfare of the building occupants or population at large. Fire tests conducted by Factory Mutual (FM) has shown that the presence of smoke and heat vents with ESFR sprinklers provides no benefit to fire control and may impede the operation of the automatic sprinkler system. Elimination of the smoke and heat vents provides a more reliable, practical, and effective fire protection program and ensures the automatic sprinkler system activation in no impeded.

□ Negligible

□ Unknown